



Specification  
CM69 TRMS AC Earth  
Leakage Clamp Meter



**ELECTRICAL**

All specified accuracies are at 23°C ± 5°C, <80% RH for 1 year.

**Temperature coefficient:** Add 0.1 x (specified accuracy) per °C. (0°C to 18°C, 28°C to 40°C).

All accuracies below are expressed as ± (percentage of reading + digits)

**DC Voltage**

Range	Resolution	Input impedance	Accuracy
60V	0.01V	2MΩ	1.0% + 2
600V	0.1V		

Overload protection: 660V DC or AC rms

**AC Voltage (True RMS)**

Range	Resolution	Input impedance	Accuracy (50 to 500Hz)
60V	0.01 V	2MΩ	1.0% + 3
600V	0.1 V		

Crest factor: 2.0

Overload protection: 660V DC or AC rms



Specification  
CM69 TRMS AC Earth  
Leakage Clamp Meter

**GENERAL**

Display: Liquid crystal display with maximum reading 6000

Sample rate 2 times/sec

Polarity: automatic, positive implied, '-' for negative polarity indication

Overrange: (OL) is displayed

Power: 2 x 1.5V, AAA alkaline batteries (IEC LR03, NEDA 24A)

Battery life (alkaline): 40 hours typical for ACV, ACmA and ACA ranges  
60 hours typical for DCV and resistance ranges

Low battery indication: symbol is displayed

Auto power off: after 30 minutes

Jaw opening capability: 23mm

Dimensions: 206 x 76 x 33.5mm

Weight: 262g approx. including batteries

Includes: carrying case, set of TL16 test leads, 2 x 1.5V AAA batteries, instructions

**ENVIRONMENTAL**

Temperature & Humidity

(Operating): 0°C to 40°C <80% R.H., non-condensing

(Storage): -10°C to 60°C <70% R.H., batteries removed

Altitude: up to 2000m

Pollution degree: 2

**SAFETY**

Conforms to: BS EN 61010-1, BS EN 61010-2-032, CAT IV 300V,

CAT III 600V

Class II, double insulation

**EMC**

Conforms to BS EN 61326-1



Specification  
CM69 TRMS AC Earth  
Leakage Clamp Meter

**AC Current (True RMS)**

Range	Resolution	Accuracy	
		(50 to 60Hz)	60 to 500Hz or LPF selected
6mA	0.001mA	1.0% + 8	2.0% + 8
60mA	0.01mA	1.0% + 5	2.0% + 5
600mA	0.1mA		
6A	0.001A		
60A	0.01A		

Crest factor: 2.0

Overload protection: 100A DC or AC rms

Low pass filter

Cut-off frequency: 160Hz approx

Attenuation characteristic: -24dB/octave approx

**Resistance**

Range	Resolution	Open circuit voltage	Accuracy
600Ω	0.1Ω	2.2V dc	1.0% + 2
6kΩ	0.001kΩ		
60kΩ	0.01kΩ		
600kΩ	0.1kΩ		

Overload protection: 600V DC or AC rms

**Continuity**

Open circuit voltage	Audible indication
2.8V dc	<55±10Ω

Overload protection: 600V DC or AC rms



Specification  
CM69 TRMS AC Earth  
Leakage Clamp Meter

**SPECIFICATION FOR TL16 TEST LEADS**

Maximum voltage: 1000V AC/DC

Maximum current: 10A continuous

Connector: 4mm banana plug with fixed shroud

**Environmental**

Temperature (Operating & Storage): 0°C to 40°C

Altitude: up to 2000m

Pollution degree 2

**Safety**

Conforms to BS EN 61010-031, CAT IV 600V, CAT III 1000V, 10A (Probe tip

covers fitted)

CAT II 1000V, 10A (Probe tip covers

removed)

Class II, double insulation

Martindale Electric Company Limited  
Metrohm House, Imperial Park, Imperial Way,  
Watford, Hertfordshire, WD24 4PP

Tel: +44 (0)1923 441717 Fax: +44 (0)1923 446900

E-mail: sales@martindale-electric.co.uk

Website: www.martindale-electric.co.uk

© 2015 Martindale Electric Company Ltd.  
Registered in England No. 3387451. Rev1 LITCM69